

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-1130:142

Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Honeywell Inc., 1500 W. Dundee Rd., Arlington Heights, IL 60004-1472
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

DESIGN: Models TC807B1000 and *TC807B1059 ionization smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. Intended for vertical wall surface or the ceiling.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as ionization smoke detectors when used in conjunction with listed Models 14506414-002 or 14507371-001 bases (CSFM Listing No. 7300-1130:146) and listee's separately listed compatible fire alarm control units. * Model TC807B1000 suitable for open area protection at air velocities up to 500 ft/min. *Model TC807B1059 suitable for open area protection at air velocities up to 1200 ft/min.

*Rev. 1-20-2003 IPI



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JANUARY 20, 2003**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager